

1) First floor residential, N16

	PM ₁	PM _{2.5}	PM ₁₀	NO ₂	CO	CO ₂	VOC	T	RH
	µg/m ³				mg/m ³	ppm	ppm	°C	%
Room 1	23	25	33	136	-	1668	1713	23.6	48.2
Room 2	25	27	33	158	1.577	1378	1083	23.3	48.8
Room 3	4	42	75	150	1.537	1300	988.5	21.7	49.8
Outdoor	15	16	16	121	8.149	488	160	12.3	69.6

2) Mechanically Ventilated First floor commercial, Central London, W1W

	PM ₁	PM _{2.5}	PM ₁₀	NO ₂	CO	CO ₂	VOC	T	RH
	µg/m ³				mg/m ³	ppm	ppm	°C	%
Room 1	9.5	10	10.5	142.88	-	659	-	22.3	48
Room 2	10	10.5	13.5	155.1	-	653	-	22.5	46.4
Room 3	28.5	29.5	41	136.3	-	-	-	-	-
Room 4	15.5	16.5	29.5	178.67	-	-	0.7	-	-
Room 5	25	26	30	138.96	-	590	-	24.6	52.4
Room 6	24.42	25.41	33.99	140.83	-	-	-	-	-
Room 7	17.5	18.5	28.5	112.8	-	-	1.8	24.6	51.3
Outdoor	19	19	19	269.25	-	529.65	0.6	22.9	49.2

3) Ground Floor Retail, Central London, WC1B

	PM ₁	PM _{2.5}	PM ₁₀	NO ₂	CO	CO ₂	VOC	T	RH
	µg/m ³				mg/m ³	ppm	ppm	°C	%
Room 1	46	47	52	160	-	501	-	21.2	55.4
Outdoor	-	-	-	248	-	-	-	12.9	-

4) Mechanically Ventilated Residential Apartment, Colindale, NW9

	PM ₁	PM _{2.5}	PM ₁₀	NO ₂	CO	CO ₂	VOC	T	RH
	µg/m ³				ppm	ppm	ppm	°C	%
Room 1	50	52	66	81	-	-	-	25.1	51.4
Room 2	47	49	62	90	-	-	-	24.4	52.8
Room 3	33	35	39	89	-	-	n	21.7	49.8
Outdoor	12	14	106	213	-	620	0	17	70

5) Mechanically Ventilated Residential Apartment, Uxbridge, UB10

	PM ₁	PM _{2.5}	PM ₁₀	NO ₂	CO	CO ₂	VOC	T	RH
	µg/m ³				ppm	ppm	ppm	°C	%
Room 1	-	-	-	110	-	420	1410	20	60
Outdoor	10.3	10.4	108	213	-	360	360	16	70

6) Residential, Wycombe HP13

	PM ₁	PM _{2.5}	PM ₁₀	NO ₂	CO	CO ₂	VOC	T	RH
	µg/m ³				ppm	ppm	ppm	°C	%
Room 1	21	22	27	96	-	1875	550	21.9	56
Room 2	29	31	65	149	-	1002	533	22.4	52.6
Outdoor	15	16	20	115	-	650	307	20	54.5